

TAG-OUT COMPLIANCE

Do all your Tags pass the OSHA test?

Check your Tags against OSHA's requirements for full compliance – **it could save a life!**

OSHA says all Lock-Out Tags must:

1. Indicate that the energy isolating device and equipment being controlled cannot be operated until the Tag is removed.
29 CFR1910.147(b)

2. Be constructed and printed so that exposure to water and moisture will not deteriorate the tag or make its message illegible.
29 CFR1910.147(c)(5)(ii)(A)(2)

3. Identify the employee applying the device(s).
29 CFR1910.147(c)(5)(ii)(D)

4. Where tag out devices are used with energy isolating devices designed with the capability of being locked, the tag attachment shall be fastened at the same point at which the lock would have been attached
29 CFR1910.147(d)(4)(iii)

5. Warn against hazardous conditions if the machine or equipment is energized and shall include the appropriate legend, such as, Do Not Start, Do Not Energize...
29 CFR1910.147(c)(5)(iii)

